



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Designation:	25 bar Piston Flow (PFS) Bar Engineered Clean Agent Fire Suppression System Designed for use with Chemours Company FM-200® Clean Extinguishing Agent
Flow Calculation Software:	Masteco Software Design Program Version MAS4.00
Design, Installation, Operation, Maintenance, Software, and Owner's Manuals:	Masteco FM-200 Easy Flow System and FM-200 Piston Flow System Engineered Clean Agent Fire Suppression System Design, Installation, Operation, and Maintenance Manual, MM-FM200-01, dated June 2017 Masteco Flow Calculation Software Version 4 User's Manual, MN-01, dated February 2015

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Masteco Industry Co., Ltd.
715-2 Gojan-dong, Namdong-gu
Incheon 405-821
Korea

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

Approval Standards

Class Number

5600

Date

April 2013


FM Approvals Listing Class: 5612

Original Approval Project Identification: 3049347

Subsequent Revisions: N/A

Approval Granted: 22 June 2017

To verify the availability of the Approved product, please refer to www.ApprovalGuide.com


James E. Marquedant
Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA 02062 USA

22 June 2017

Date

