

CERTIFICATE OF COMPLIANCE

Certificate Number 20160418-EX26626
Report Reference EX26626-20160415
Issue Date 2016-APRIL-18

Issued to: MASTECO INDUSTRY CO LTD
715-12 146 Bl 13Lt Gojan-Dong
Namdong-Gu
Incheon 405-821 KOREA

This is to certify that representative samples of MASTECO INDUSTRY CO LTD
Automatic sprinklers, incorporating 3 mm and 5 mm
frangible glass bulbs in the following models:
MT2500,MT2600,MT2510,MT2610


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 199 and ULC/ORD-C199, Automatic Sprinklers for
Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

