

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20141127-EX15244  
**Report Reference** EX15244-20070621  
**Issue Date** 2014-NOVEMBER-27

**Issued to:** MASTECO INDUSTRY CO LTD  
715-12 146 BL 13LT GOJAN-DONG NAMDONG-GU  
INCHEON 405-821 KOREA

**This is to certify that  
representative samples of**

CHECK VALVES  
Models MGCV-2G, MGCV-2.5G, MGCV-3G, MGCV-4G  
and MGCV-6G spring loaded swing check valves with  
grooved ends in sizes 2, 2-1/2, 3, 4, and 6 in. for pressures  
not exceeding 300 psig. The check valves are intended for  
installation in both the horizontal and vertical positions.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Check Valves for Fire-Protection Service, UL 312 And  
ULC/ORD-C312

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

