



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

| | |
|-------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| System Designation: | 25 bar Easy Flow (EFS) Bar Engineered Clean Agent Fire Suppression System Designed for use with Chemours Company FM-200® Clean Extinguishing Agent |
| Flow Calculation Software: | Masteco Software Design Program Version MAS4.00 |
| Design, Installation, Operation, Maintenance, Software, and Owner's Manuals: | Masteco FM-200 Easy Flow System and FM-200 Piston Flow System Engineered Clean Agent Fire Suppression System Design, Installation, Operation, and Maintenance Manual, MM-FM200-01, dated June 2017 Masteco Flow Calculation Software Version 4 User's Manual, MN-01, dated February 2015 |

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Masteco Industry Co., Ltd.
715-2 Gojan-dong, Namdong-gu
Incheon 405-821
Korea

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

| <i>Approval Standards</i> | <i>Date</i> |
|-----------------------------|-------------|
| <i>Class Number</i> 5600 | April 2013 |

FM Approvals Listing Class: 5612

Original Approval Project Identification: 3049347
Subsequent Revisions: N/A

Approval Granted: 22 June 2017

To verify the availability of the Approved product, please refer to www.ApprovalGuide.com




James E. Marquedant
Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA 02062 USA

22 June 2017

Date