

CERTIFICATE OF COMPLIANCE

Certificate Number 20160415-EX15719
Report Reference EX15719-20150121
Issue Date 2016-APRIL-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models MFC-50, -75, -100 and -150, Clean Agent Extinguishing System Units containing FM-200 (HFC-227ea), stored pressure type, having nominal storage capacities of 50, 75, 100 and 150 kg of FM-200 (HFC-227ea), respectively. The units are super-pressurized with dry nitrogen to 25 bar at 70°F (21°C) with operating temperatures of 32°F to 130°F (0°C to 55°C). The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

These systems are intended to be designed and installed in accordance with the Listee's design, installation and maintenance manual, Part No. MM-FM200-01 dated April 2016 and Masteco HFC-227ea Flow Calculation Software, Version MAS4.00.

Agent Cylinder Valve Assemblies

Model	Nominal Volume Of Agent (L)	Fill Range (kg)	Charging Pressure (bar @21°C)	Valve Outlet Size	Part No.
MFC-50	63.0	31.2 – 60.6	25	40A	CVL-R40
MFC-75	89.0	44.1 – 85.6	25	40A	CVL-R40
MFC-100	115.4	57.2 – 111.0	25	50A	CVL-R50
MFC-150	175.0	86.7 – 168.3	25	50A	CVL-R50



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

